



* LCCC read 65 psi, 18.5 gpm

Contractor to field verify pressure and GPM for their design.

*Laramie County Community College
Community Garden*