

LARAMIE COUNTY COMMUNITY COLLEGE
1400 East College Drive, Cheyenne WY 82007

ADDENDUM NO. 1

IFB No.: IFB-16047
Description: Interior Lighting Project
Addenda Date: September 23, 2015

NOTE: Receipt of this Addendum must be acknowledged via this written instrument known as Addendum No. 1 and submitted with your Proposal/Bid. NO EXCEPTIONS.

Participants are hereby notified that the aforementioned Bid has been revised and supplemented in accordance with this certain Addendum. Where provisions of this Addendum differ from those of the original Bid, this Addendum shall govern and take precedence. Applicants shall make all necessary adjustments to their proposal/bid submittals for revisions defined per this Addendum. This Addendum is hereby incorporated by reference and made a part of and condition of IFB-16047.

SCOPE OF ADDENDUM

Sign-in sheet from mandatory pre-bid meeting is attached.

There will be no plan review required for the awarded contractor, but contractor will need to apply for a county permit (for inspection).

Pre-bid meeting questions & answers:

1. What is the cost estimate for the project? LCCC does not give out cost estimates on projects.
2. Can contractors work nights/ weekends to get work done? The initial phase is scheduled while school is on Christmas break so the rooms should be available. The remaining sections can be scheduled in the summertime when school is not in session or in some buildings, contractors can work around the occupants (like in the Plant Operations building).
3. Are there existing fixtures that need to be disposed of that have PCB in them? Maybe, but not positive on the count. If PCB ballasts are found, deliver the ballasts to the owner, who will dispose of them.
4. Do we want certificates of disposal? Yes
5. When were the buildings built?
 - a. Plant Operations – 1979
 - b. Auto Body – 1975
 - c. Construction Technology – 1979
 - d. Physical Education – 1973
6. Are we working with Cheyenne Light Fuel & Power for rebates? Yes, we will want contractor to work with owner and CLFP for rebates.
7. What are the lead times for the fixtures? As of 9/2/15 all fixtures were noted to have lead times under 5 weeks except for the racquetball fixture which was 7-8 weeks. These times are approximate and subject to change.

8. For the fixtures on hard ceilings, are the contractor's responsible for paint touch-ups? LCCC has revised the pricing sheet for IFB-16047 (attached to addendum) and all bidders should respond on the revised price sheet, which includes a line for the cost for paint touch-ups by contractor.

This Addendum consists of a total of two (2) pages and must be signed and submitted with your Proposal/bid.

Authorized Signature for Company

Name of Company

- Original Copy in Mail
 Copy sent electronically on September 23, 2015
 Copy sent via facsimile transmission