

Addendum Number 4
Laramie County Community College
South Irrigation System Rehabilitation
January 9, 2017

Addendum Number 4 applies to the above listed project.

Pre-Bid Contractor questions and responses:

- 1) Clarification: Sheet E-2 Where is #3 on the New Electrical Plan. I don't see it.
 - a) Note 3 was intended to reference a new section of conduit connected to the existing conduit tagged by keynote 4 which terminates inside the existing compressor building. Provide a 2" conduit between that point and the new pump control panel.

Kelly W. Hafner

Kelly W. Hafner, P.E.
BenchMark Engineers, P.C.

Note: All bidders must acknowledge receipt of this addendum with the submittal of their bid.

END OF ADDENDUM 4