

**Addendum Number 5**  
Laramie County Community College  
South Irrigation System Rehabilitation  
January 9, 2017

---

**Addendum Number 5** applies to the above listed project.

Pre-Bid Contractor questions and responses:

- a) Clarification for Vault A (Meter Vault): two (2) access (30-inch min. clear) are acceptable for access into the vault/meter pit. The entire lid does not have a grated opening.

*Kelly W. Hafner*

---

Kelly W. Hafner, P.E.  
BenchMark Engineers, P.C.

**Note: All bidders must acknowledge receipt of this addendum with the submittal of their bid.**

**END OF ADDENDUM 5**